

No F 6 / DFS / MS / 2015 / School / 2015 / 2089

Dated: 20 / 11 / 2015


FIRE SAFETY CERTIFICATE

Certified that the Arvind Gupta DAV Centenary Public School located near Naini Lake Model Town Delhi comprised of Ground and 03 upper floors owned/occupied by DAV College Managing Committee was issued fire safety certificate vide this office letter no F6/DFS/MS/2012/school/1899 Dated 24/05/2012. The premise was re-inspected by the officer concerned of Fire service on 29.09.2015 in the presence of Sh K L Chaudhary/Suptd and observed that all the fire prevention and fire safety arrangements provided in accordance with the circular issued by Director of Education letter no 3298-3398 dated 01.03.2011/NBC Part 4 and found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy Group B Educational with effect from20/11/15... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Issued on20/11/15..... at New Delhi


(Santokh Singh)
Chief Fire Officer
Ph:-011-23414250

Copy to:

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal, Arvind Gupta DAV Centenary Public School, Naini Lake Model Town Delhi.